



FUEL TANK MAINTENANCE CHECKLIST

Make sure all openings are tightly closed to keep rainwater out
Ensure drain valves are securely closed
Check for overfills and low-level
Test and confirm that containment alarms are working correctly
Check that pumps turn on and run smoothly without any noises or issues
Keep the tank locked or secured to prevent unauthorised access
Remove any plants or debris around the tank
Check if the lid and containment area is secure and free from water or debris
Inspect the base to ensure the tank's weight is evenly distributed
Create a safe and clear pathway to access the tank
Look for any discolouration on the ground and check for oil signs near valves, pipes, and seams of the tank
Examine the tank for any signs of damage like bulges, deep scratches, cracks, rust, or corrosion (if applicable)
Verify that the monitoring device is working properly
Check if the overfill prevention system is functioning correctly
Ensure the leak detection system is accurately monitoring any leaks

Unit 8, South Staffs Terminal, Lynn Lane, Shenstone, Staffs

0121 308 6938 | sales@neuks.co.uk







